CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7165-1126:117 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Interactive Technology Inc, 2266 Second St North, North Saint Paul, MN 55109

Contact: Randy Liberskyl (651) 773-2235

DESIGN: Model 4720 fire alarm control unit. Manual, automatic, waterflow, local or central station service.

Inherently power-limited. Refer to listee's data sheet for detailed product description and

operational considerations. Basic local system:

4720 Control Unit4724* Control Expander

4195 Auxiliary Power Supply/Battery Charger

4160 Bell Supervisory Module 9220 Power Transformers (2 each)

PS1270 Standby Batteries (2 each)

4660R, -C Keypads 4126* Zone Expander

4175 Dual Ring Detector Module 4180* Status Display Module

4115 Zone Expander

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Instructions Manual for details.

NOTE: 1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.

2. For Fire Alarm Verification feature (delay of fire alarm signal), the max. Retard/Reset/Restart shall not exceed 30 seconds.

*Rev. 10-01-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 2, 2001 Listing Expires June 30, 2002

Authorized By: **BEN HO**, Supervising Deputy

Program Manager